



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20182019/40274

Date: 26-09-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: DWARKAPATI DEALCOM PRIVATE LIMITED
217, VIVEHANANDA SARANI, MOUZA - ELAICHI, WARD NO.- 26, J.L. NO.- 70, DIST.- 24 PGS(S), BARUIPUR F.S.,
SONARPUR, SOUTH 24 PARGANAS, KOLKATA - 700150.

Sub: Part Fire Safety Certificate for wing 1 & 2 up to 2nd floor of an Existing construction of 1 no. Block
Comprising 3 no's wings i.e., wing 1 & 2 - of G+IV storied (height - 24.5 mtr) Wing 3 of single storied (Height -3.75
mtr) under group Educational Building in the name of DWARKAPATI DEALCOM PRIVATE LIMITED. at 217,
VIVEHANANDA SARANI, MOUZA - ELAICHI, WARD NO.- 26, J.L. NO.- 70, DIST.- 24 PGS(S), BARUIPUR F.S.,
SONARPUR, SOUTH 24 PARGANAS, KOLKATA - 700150

This is in reference to your application no. 0125189221200048 dated 07-03-2022 regarding the Part Fire Safety Certificate
for wing 1 & 2 up to 2nd floor of an Existing construction of 1 no. Block Comprising 3 no's wings i.e., wing 1 & 2 - of G+IV
storied (height - 24.5 mtr) Wing 3 of single storied (Height -3.75 mtr) under group Educational Building in the name of
DWARKAPATI DEALCOM PRIVATE LIMITED. at 217, VIVEHANANDA SARANI, MOUZA - ELAICHI, WARD NO.- 26, J.L.
NO.- 70, DIST.- 24 PGS(S), BARUIPUR F.S., SONARPUR, SOUTH 24 PARGANAS, KOLKATA - 700150

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found
satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the
aforesaid building.

Recommendation:

To up-keep the Fire Safety Measures of the aforesaid building the following safety measures need to be incorporated /
maintained:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
3. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
4. A fire control room including a closed-circuit TV system shall have to be installed which observe all the floors of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the
Unique Number : 0125189221200048.

Page : 1

building.

5.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.

6.The employees and security staff shall be conversant with installed firefighting equipment's of the building and to operate in the event of fire and testing.

7.Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

8.A crew of trained Firemen shall be maintained round the clock for fire safety of the building.

9.First Aid firefighting system shall be provided as per I.S. specifications.

10.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.

11.Periodical flashing of water in the Hydrants Pipelines shall be made to maintain the efficient working performance of above-mentioned system.

12.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

13.This Fire Safety Certificate is valid for Three Years and has to be renewed from the date of issue of this letter.

14.The Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Director
West Bengal Fire & Emergency Services

Government of West Bengal
Office of the Director General
W.B. Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata-700016

Memo No. - WBFES/ 3247/23/ e/3135/18-19

Date-25/07/23

From: Director
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street
Kolkata- 700016


To: Dwarkapati Dealcom Pvt. Ltd.
M.K. Point
27, Bentinct Street
2 nd. Floor, Room No. 203 & 204
Kolkata
West Bengal- 700001

Sub: Change of name in the Part Fire Safety Certificate issued in memo no. IND/WB/FES/20182019/40274 dated 26.09.2022 in respect of educational building situated at 217, Vivekananda Sarani, Mouza- Elaichi, Ward No.- 26, J.L. No.- 70, Dist.- 24 Parganas South, P.S.- Sonarpur, Kolkata- 700150.

Ref.: Your letter being received by this Directorate on 03.07.2023.

In reference to your letter received by this office vide docket no. 10158 dated 03.07.2023 regarding change of recipient name from DWARKAPATI DEALCOM PRIVATE LIMITED to Delhi World Public School (under the aegis of Gyan Bharti Educational Trust).

The undersigned would like to inform that as per desire of the Director, Dwarkapati Dealcom Pvt. Ltd. and based on submitted relevant documents future correspondence will be done with Delhi World Public School (under the aegis of Gyan Bharti Educational Trust).


Director
West Bengal Fire & Emergency Services